

## RESULTS OF MICROBIOLOGICAL WATER ANALYSIS

Client: ECOLE DU NORD

07.09.2021

Date Collected: 02.09.2021

Time Collected: 11H30

Date Submitted: 02.07.2021

Number of samples: 15 (WATER)

From (Name of person who has taken the samples): Jessica Follette.

Result for: [WATER ANALYSIS](#)

No:	Your reference	Source	Coliform Total MPN/100ml	Ecoli Total MPN/100ml
1	WATER	CANTINE ZONE 2	ND	ND
2	WATER	FONTAINE PREHAUT ZONE 2	ND	ND
3	WATER	FONTAINE ZONE 2	ND	ND
4	WATER	PRIMAIRE	ND	ND
5	WATER	SECONDAIRE	ND	ND
6	WATER	POLE SCIENCE	ND	ND
7	WATER	CANTINE ZONE 1	ND	ND
8	WATER	FONTAINE ZONE 1	ND	ND
9	WATER	MATERNELLE 2	ND	ND
10	WATER	PETITE SECTION 2	ND	ND
11	WATER	GYMNASE	ND	ND
12	WATER	FONTAINE CM2	ND	ND
13	WATER	PETITE SECTION 1	ND	ND
14	WATER	MATERNELLE	ND	ND
15	WATER	SALLE DE MAITRE	ND	ND

**ND: NOT DETECTED**

**ACCEPTABLE RANGE: Less than 20 CFU**

